



**Building & DIY Products You Can Trust** 

Site 41, Knowsthorpe Way, Cross Green Industrial Estate, Leeds, LS9 0SW Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424 Fax: +44 (0) 113 240 0024 e-mail: info@everbuild.co.uk website: www.everbuild.co.uk

## **CONSTRUCTION PRODUCTS REGULATION**

## **DECLARATION OF PERFORMANCE**

## No: 1121-CPR-JA5018

1. Identification Code	FIRE SEALANT 400
	Codes: 400 BK / GY / WE
2. Type, Batch and/or Serial	- For batch number - see packaging
Number	
3. Intended use	Fire Stopping and Sealing Product for Linear Joint and Gap Seals,
	see ETA 13/1059
4. Manufacturer	Everbuild Building Products ltd, Site 41, Cross Green Industrial
	Estate, Knowsthorpe Way, Leeds, LS9 0SW
5. Authorised Representative	Not Applicable
6. Assessment and Verification	System 1
of Constancy of Performance	
7. Notified Body and Tasks	Exova Warringtonfire 1104
8. European Technical	Exova Warringtonfire issued European Technical Approval ETA
Assessment	13/1059 on the basis of ETAG 026, edition 2011, used as European
	Assessment Document (EAD)
9. Declared Performance	TO ETAG 026 Edition 2011
Reaction to Fire	Class E
Resistance to Fire	Resistance to fire performance and field application in accordance with
	En 13501-2. See ETA 13/1059



## **Building & DIY Products You Can Trust**

Site 41, Knowsthorpe Way,

Cross Green Industrial Estate, Leeds, LS9 0SW

Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424

Fax: +44 (0) 113 240 0024 e-mail: info@everbuild.co.uk

website: www.everbuild.co.uk

Air Permeability	Tested according to EN1314-1 see ETA 13/1059
Dangerous Substances	See Clause 2.5
Airborne sound insulation	Rw(C;Ctr) = 38 (-2;-9)
Durability and serviceability	Z <sub>1</sub>
Movement Capability	According to ISO 11600 F25LM

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed: I. G. Southerington – Head of Technical

P.R. Thomas – Technical Manager

Julle

Dated: Leeds, 1/4/14